

## FIRE SAFETY MANAGEMENT PLAN

Establishment's Address	
Fire Safety Plan Person with overall responsibility for fire safety at the equine establishment	Responsible Person
Organisation: Setting objectives, design of tasks Planning: Structure of the establishment	
Control: Identity of persons responsible for tasks Monitoring: Regular inspections to check implementation of standards and management controls Review: Review standards and performance	Position
Fire Risk Assessment Person responsible for:	Responsible Person
<ul> <li>Carrying out the fire risk assessment</li> <li>Maintenance and review of the fire risk assessment</li> </ul>	Position
Maintenance Programme Person responsible for :	Responsible Person
<ul> <li>The maintenance of all fire safety arrangements</li> <li>The fire warning arrangements</li> <li>The provided fire-fighting equipment</li> </ul>	
<ul> <li>High standards of house keeping</li> <li>The control of all visitors and contractors</li> <li>Nominating persons for calling the emergency services</li> </ul>	Position
<ul> <li>The emergency release arrangements for the horses</li> <li>The availability of water supplies for fire fighting</li> <li>Ensuring a clear access for the emergency vehicles</li> </ul>	
<b>Emergency Action Plan</b> The person responsible for the emergency action plan, which details the procedures to be taken by <b>all</b> persons in the event of fire at the equine establishment.	Responsible Person
	Position
Staff Training Person responsible for all the fire safety training for staff or other persons at the equine establishment.	Responsible Person
	Position



## EXAMPLES OF IDENTIFIED FIRE HAZARDS AND RISKS

LOCATION	INDENTIFIED FIRE HAZARD OR RISK	EVALUATE INDENTIFIED PERSONS OR HORSES	ACTIONS TO REDUCE REMOVE OR CONTROL	INFORMATION RECORDED AND
		CONSIDERED AT	THE HAZARD OR RISK	REVIEW DATE
		SIGNIFICANT RISK		
Example Tack Room	LPG Portable radiant gas	All persons using the tack room.	Remove LPG radiant gas	Action recorded in stable's
	heater used for drying damp	Horse stabled in end stable next	heater from tack room.	fire logbook.
	blankets. Located in	to tack room.	Review arrangements for	Names of staff advised of
	combustible wooden end		drying damp blankets.	action,
	section of stable building.		Provide less hazardous types of	Review in three month's time.
			heaters. Issue instructions to	
			staff no to use radiant type	
			heaters.	



